Emission Summary

Source Status: New Modifica	tion Expansion Reloca	tion Permit Status:	New⊠ Renewal□
PSD□ NSPS⊠ NESHAPs⊠	Previous Permit Number:	Construction	Operating

968064P

Permit Number:

	Pounds/Hour				Tons	/Year		Date of	*	Applicable Standard
	Actual	Potential	Allowable	Actual	Potential	Allowable	Net Change	Data		
	-									
PM**			0.05			0.01		12/2/13	1	1200-03-0602(2) 40 CFR part 60 Subpart IIII
SO ₂			neg			neg		12/2/13	2	1200-03-1403(5)
CO**			0.61			0.15		12/2/13	1	1200-03-0707(2) 40 CFR part 60 Subpart IIII
VOC**				,				12/2/13	1	1200-03-0707(2) 40 CFR part 60 Subpart IIII
NO _x **			0.57	-		0.14		12/2/13	1	1200-03-0707(2) 40 CFR part 60 Subpart IIII
HAPs					neg	na		12/2/13	3	
CO ₂ e	*				21.2	na		12/2/13	5	

The above emission data are from emission test results required by the EPA's engine certification program. The SO₂ emissions were calculated using 15 ppm sulfur content of the fuel (NSPS requirement), assuming all available sulfur is converted to SO₂

PERMITTING PROGRAM: <u>JEF</u> DATE: <u>3/6/2014</u>

^{*} Source of data codes are found on the back of form APC-20.

^{**} The allowable emission limits are subject to 40 CFR part 60 Subpart IIII. This emergency engine must meet the emission requirements in $\S60.4205(b)$ & $\S89.112$, Table 1, Tier 3. The applicable standard for NO_x is in terms of $NO_x + NMHC$. Therefore, the allowable VOC emissions are accounted for in NO_x .

City of Bradford - City Hall

27-0239-01/968064P

74 horsepower diesel-fired, emergency generator engine.

					NSPS	
					regulation	
Model	Model yr	br-hp	KW	MMBtu/hr	(40 CFR X)	MACT?
John Deere 4045TF290	2013	74	55	0.518	89	YES

Potential to emit (at 500 hr/yr)

Pollutant	Factor (lb/hp- hr)	Factor (gm/kW-hr)	Emissions (gm/hr)	Emissions (lb/hr)	Emissions (tpy)				
PM		0.29	15.95	0.04	0.01				
NO _x + NMHC		4.6	253.00	0.56	0.14				
CO		1.2	66.00	0.15	0.04				

Spec sheet from John Deere indicates the engine is certified Tier 4 interim Emission factors from CARB certificate

Allowable emissions per engine, 40 CFR 89.112

Pollutant	Standard (gm/kW-hr)	Emissions (gm/hr)	Emissions (lb/hr)	Emissions (tpy)
NMHC + NOx	4.7	258.5	0.57	0.14
CO	5.0	275	0.61	0.15
PM	0.4	22	0.05	0.01

1 lb = 453.592 gm

1 br-hp = 0.7451 kW

1 hp-hr = 7,000 Btu, average

HAPs totals from diesel		
combusion	lb/MMBtu	tpy
Benzene	9.33E-04	0.0001
Toluene	4.09E-04	0.0001
Xylenes	2.85E-04	0.0000
Propylene	2.58E-03	0.0003
1,3 Butadiene	3.91E-05	0.0000
Formaldehyde	1.18E-03	0.0002
Acetaldehyde	7.67E-04	0.0001
Acrolein	9.25E-05	0.0000
PAHs	1.68E-04	0.0000
		0.0008

For SO_2 , 15 ppm maximum sulfur content of fuel. Assume all sulfur converted to SO_2

Every mole of sulfur will create one mole of sulfur dioxide

 $S + O_2 \longrightarrow SO_2$

29.9 gal fuel	15 lb S	mol S	mol SO ₂	64.066 lb SO ₂	0.0008961	lb /b = CO2
hr	10 ⁶ gal fuel	32.065 lb S	mol S	mol SO ₂		10/111 302
from spec sheet	from NSPS	Assume a	all sulfur conve			

Greenhouse gases

CO₂ EF	CH ₄ EF	N ₂ O EF	CO ₂ e (tpy)
(kg/MMBtu)	(kg/MMBtu)	(kg/MMBtu)	
73.96	0.003	0.0006	21.2 @ 500 hr/yr

Negligible SO_2 and GHG emissions

CONSTRUCTION PERMIT SUMMARY REPORT

Company Name:	City of B	radford – City H	all	File	e Number:	27-0239	EPS	S Initials:	JEF	
Permit Number(s):		968064P		Source Point Number(s): _01						
Application Receive	d (date):	12/10/2013		Application Complete (date): 12/10/2013						
Air Quality Analysis	s Performe	d? Yes□ No∑								
expected, qualitative	e) (replacin	combustion die	(background info	ormatic (74.0	on) hp) used for	or an emerger	ncy gener	ator. This	s emergency	
Engines. Additional in subpart IIII. This	ly, the eng	ine will meet the	e engine MACT	(40 CF						
The expecte this source.	ed emission	ns from this sour	ce are PM, SO ₂ ,	CO, V	OC, NO _x . Po	ollution contro	l equipmo	ent is not	proposed for	
			Rules A	analy	rsis					
Title V Cond.	Major 🗌	Minor⊠	Source catego	ry liste	ed in 1200-	03-0901(4)(b)1.(i)?	Yes	No⊠	
Reason for PSD: Applicable NSPS:			above TPY 50, Subpart 4I		_	crease in e 1200-03-16	emissions		N/A ⊠ N/A ⊠	
Applicable NESHAP:			51, Subpart			e 1200-03-11 e 1200-03-31			N/A ⊠ N/A ⊠	
			Other Applica	ble Sta	te Rules					
TSP Emissions: SO ₂ Emissions: CO Emissions: VOC Emissions:	1200-03- 1200-03- 1200-03- 1200-03-	06 02(2) 14 03(5) 07 07(2) 07 07(2)	N/A	NO _x	Emissions: _ Emissions: _ Emissions: _ Emissions:	1200-03- 1200-03- 1200-03- 1200-03-			N/A N/A N/A N/A N/A N/A	
Visible Emissions from	-	Source	not to exceed	_20_	% opacity p				05 - 03(6)	
Visible Emissions from Visible Emissions from			not to exceed		% opacity po			e 1200-03- e 1200-03-		
Comments:										

HEADER

The applicant is the <u>City of Bradford (City Hall)</u> with a mailing address of <u>216 E. Main Street, Bradford, TN 38316</u>. They seek to obtain an air contaminant permit (Division identification number: <u>27-0239-01/68064</u>) for an <u>Electric Power Generator</u> located at the same address. This proposed operation would consist of a diesel fuel-fired electric power generator and associated equipment used to provide emergency backup electric power for the city hall building. Because of the amount and type of emissions, the use of pollution control equipment is not proposed. There would be physical construction. Regulated air contaminants would be emitted by this source. Mr. E. King is the assigned Division person.

For the Gibson County "Milan Mirror-Exchange"-- publish once on or before Thursday, February 6, 2014.